



Ref. Certif. No.

DK-146933-UL

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

CB TEST CERTIFICATE

Product

Uninterruptible Power Supply

Name and address of the applicant

NXT Power, LLC
1070 S Northpoint Blvd (Unit D) Waukegan, IL 60085
United States

Name and address of the manufacturer

NXT Power, LLC
1070 S Northpoint Blvd (Unit D) Waukegan, IL 60085
United States

Name and address of the factory

Ablerex Electronics Co., Ltd,
1F., No. 3, Ln. 7, Baogao Rd,
Xindian Dist., New Taipei City
231029,
Taiwan (R.O.C)

Note: When more than one factory, please report on page 2

Additional Information on page 2

Ratings and principal characteristics

Models: NPTU1500-L-i, NPTU1500-LM-i
AC Input~: 208-240 Vac, 6.9 A, 50/60 Hz, single-phase.
 Additional Information on page 2

Trademark / Brand (if any)



Customer's Testing Facility (CTF) Stage used

Model / Type Ref.

NPTU1100-L-i, NPTU1100-LM-i, NPTU1500-L-i, NPTU1500-LM-i

Additional information (if necessary may also be reported on page 2)

Additional Information on page 2

A sample of the product was tested and found to be in conformity with

IEC 62040-1:2008, IEC 62040-1:2008/AMD1:2013

As shown in the Test Report Ref. No. which forms part of this Certificate

E166979-4789912840-1 Reissue 1 issued on 2023-10-25

This CB Test Certificate is issued by the National Certification Body



- UL Solutions (US), 333 Pfingsten Rd IL 60062, Northbrook, USA
- UL Solutions (Demko), Borupvang 5A DK-2750 Ballerup, DENMARK
- UL Solutions (JP), Marunouchi Trust Tower Main Building 6F, 1-8-3 Marunouchi, Chiyoda-ku, Tokyo 100-0005, JAPAN
- UL Solutions (CA), 7 Underwriters Road, Toronto, M1R 3B4 Ontario, CANADA

For full legal entity names see www.ul.com/ncbnames

Date: 2023-12-19

Signature:

Thomas Wilson



Ref. Certif. No.

DK-146933-UL

Additional Ratings:

AC Output~:

208 Vac, 5.9 A, 1224 VA, 1102 W, PF=0.9 or
220 Vac, 6.3A, 1386 VA, 1247 W, PF=0.9 or
230 Vac, 6.3 A, 1440 VA, 1296 W, PF=0.9 or
240 Vac, 6 A, 1440 VA, 1296 W, PF=0.9
50/60 Hz, single-phase.

Models: NPTU1100-L-i, NPTU1100-LM-i

AC Input~: 208-240 Vac, 6.1 A, 50/60 Hz, single-phase.

AC Output~:

208 Vac, 5.3 A, 1100 VA, 990 W, PF= 0.9 or
220 Vac, 5.0 A, 1100 VA, 990 W, PF= 0.9 or
230 Vac, 4.8 A, 1100 VA, 990 W, PF= 0.9 or
240 Vac, 4.6 A, 1100 VA, 990 W, PF= 0.9
50/60 Hz, single-phase.

Additional information (if necessary)



- UL Solutions (US), 333 Pflingsten Rd IL 60062, Northbrook, USA
- UL Solutions (Demko), Borupvang 5A DK-2750 Ballerup, DENMARK
- UL Solutions (JP), Marunouchi Trust Tower Main Building 6F, 1-8-3 Marunouchi, Chiyoda-ku, Tokyo 100-0005, JAPAN
- UL Solutions (CA), 7 Underwriters Road, Toronto, M1R 3B4 Ontario, CANADA

For full legal entity names see www.ul.com/ncbnames

Date: 2023-12-19

Signature:

Thomas Wilson