


IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE)
CB SCHEME

CB TEST CERTIFICATE

Product	Uninterruptible Power Supply Equipment
Name and address of the applicant	NXT Power, LLC 7051 West Wilson Ave. Harwood Heights, IL 60706 USA
Name and address of the manufacturer	NXT Power, LLC 7051 West Wilson Ave. Harwood Heights, IL 60706 USA
Name and address of the factory <i>Note: When more than one factory, please report on page 2</i>	ZHANGZHOU KEHUA TECHNOLOGY CO LTD Beidou Industrial Zone Jinfeng Industrial District Zhangzhou, 363000 Fujian China <input type="checkbox"/> Additional Information on page 2
Ratings and principal characteristics	All Models are Single Phase and 50/60 Hz UPS Models have a short-circuit rating of 5000 A at 240 Vac. DC Rating: NPTU Series UPS: 192V(DC), 63A(MAX) Battery Cabinet Model NPB48-192: 192V(DC), 63A(MAX) For detailed model ratings see CB Test Report.
Trademark / Brand (if any)	
Type of Customer's Testing Facility (CTF) Stage used	CTF Stage 2
Model / Type Ref.	NPTU10.0-HO, NPTU10.0-O, NPTU2200-HO, NPTU2200-O, NPTU3200-HO, See Page 2
Additional information (if necessary may also be reported on page 2)	Additionally evaluated to EN 62040-1:2008/AM1:2013. National Differences specified in the CB Test Report. <input type="checkbox"/> Additional Information on page 2
A sample of the product was tested and found to be in conformity with	IEC 62040-1:2008/AMD1:2013, IEC 62040-1:2008
As shown in the Test Report Ref. No. which forms part of this Certificate	4789552427 issued on 2021-02-04

This CB Test Certificate is issued by the National Certification Body



- UL (US), 333 Pfingsten Rd IL 60062, Northbrook, USA
- UL (Demko), Borupvang 5A DK-2750 Ballerup, DENMARK
- UL (JP), Marunouchi Trust Tower Main Building 6F, 1-8-3 Marunouchi, Chiyoda-ku, Tokyo 100-0005, JAPAN
- UL (CA), 7 Underwriters Road, Toronto, M1R 3B4 Ontario, CANADA

For full legal entity names see www.ul.com/ncbnames

Date: 2021-02-04

Signature:

Jolanta M. Wroblewska



Ref. Certif. No.

US-37499-UL

Model Details:

UPS Models:

NPTU2200-HO,NPTU2200-O,
NPTU3200-HO,NPTU3200-O,
NPTU4000-HO,NPTU4000-O,
NPTU4200-HO,NPTU4200-O,
NPTU5200-HO,NPTU5200-O
NPTU6000-HO,NPTU6000-O,
NPTU8200-HO,NPTU8200-O
NPTU10.0-HO,NPTU10.0-O

Battery Cabinet Model NPB48-192,

All Models may be followed by additional suffixes

Additional information (if necessary)



UL (US), 333 Pfingsten Rd IL 60062, Northbrook, USA



UL (Demko), Borupvang 5A DK-2750 Ballerup, DENMARK



UL (JP), Marunouchi Trust Tower Main Building 6F, 1-8-3 Marunouchi, Chiyoda-ku, Tokyo 100-0005, JAPAN



UL (CA), 7 Underwriters Road, Toronto, M1R 3B4 Ontario, CANADA

For full legal entity names see www.ul.com/ncbnames

Date: 2021-02-04

Signature:

Jolanta M. Wroblewska