



Ref. Certif. No.

DK-105768-M1-UL

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

CB TEST CERTIFICATE

Product	General Purpose, Separating Power Supplies
Name and address of the applicant	NXT Power, LLC 7051 W Wilson Ave Harwood Heights, IL 60706 USA
Name and address of the manufacturer	NXT Power, LLC 7051 W Wilson Ave Harwood Heights, IL 60706 USA
Name and address of the factory	NXT Power, LLC 7051 W Wilson Ave Harwood Heights, IL 60706 USA
Note: When more than one factory, please report on page 2	<input type="checkbox"/> Additional Information on page 2
Ratings and principal characteristics	See Page 2
Trademark (if any)	
Customer's Testing Facility (CTF) Stage used	
Model / Type Ref.	NPT80-i, NPT80-H-i, NPT80-W-i, NPT80-HW-i, NPT80-i-G, NPT80-GH-i, See Page 2
Additional information (if necessary may also be reported on page 2)	The report was revised to include technical modifications. <input checked="" type="checkbox"/> Additional Information on page 2
A sample of the product was tested and found to be in conformity with	IEC 61558-1:2005, IEC 61558-2-1:2007
As shown in the Test Report Ref. No. which forms part of this Certificate	4789462418 issued on 2021-02-16

This CB Test Certificate is issued by the National Certification Body



- UL (US), 333 Pfingsten Rd IL 60062, Northbrook, USA
- UL (Demko), Borupvang 5A DK-2750 Ballerup, DENMARK
- UL (JP), Marunouchi Trust Tower Main Building 6F, 1-8-3 Marunouchi, Chiyoda-ku, Tokyo 100-0005, JAPAN
- UL (CA), 7 Underwriters Road, Toronto, M1R 3B4 Ontario, CANADA

For full legal entity names see www.ul.com/ncbnames

Date: 2021-05-06
Original Issue Date: 2020-11-17

Signature: Jan-Erik Storgaard

Model Details:

NPT80-i, NPT80-H-i, NPT80-W-i, NPT80-HW-i,
NPT80-i-G, NPT80-GH-i, NPT80-GW-i, NPT80-GHW-i,
NPT240-i, NPT240-H-i, NPT240-W-i, NPT240-HW-i,
NPT240-i-G, NPT240-GH-i, NPT240-GW-i, NPT240-GHW-i,
NPT480-i, NPT480-H-i, NPT480-W-i, NPT480-HW-i,
NPT480-i-G, NPT480-GH-i, NPT480-GW-i, NPT480-GHW-i,
NPT780-i, NPT780-H-i, NPT780-W-i, NPT780-HW-i,
NPT780-i-G, NPT780-GH-i, NPT780-GW-i, NPT780-GHW-i,
NPT1000-i, NPT1000-H-i, NPT1000-W-i, NPT1000-HW-i
NPT1000-i-G, NPT1000-GH-i, NPT1000-GW-i, NPT1000-GHW-i,
NPT1200-i, NPT1200-H-i, NPT1200-W-i, NPT1200-HW-i,
NPT1500-i, NPT1500-H-i, NPT1500-W-i, NPT1500-HW-i,
NPT2000-i, NPT2000-H-i, NPT2000-W-i, NPT2000-HW-i

Ratings:

Input and Output: 200-240 Vac, 50/60 Hz

Current Rating indicated below:

NPT80-i, NPT80-H-i, NPT80-W-i, NPT80-HW-i,

NPT80-i-G, NPT80-GH-i,

NPT80-GW-i, NPT80-GHW-i

Input: 0.4 A; output: 0.35 A

NPT240-i, NPT240-H-i, NPT240-W-i, NPT240-HW-i,

NPT240-i-G, NPT240-GH-i,

NPT240-GW-i, NPT240-GHW-i

Input: 1.15 A; output: 1.00 A

NPT480-i, NPT480-H-i, NPT480-W-i, NPT480-HW-i,

NPT480-i-G, NPT480-GH-i,

NPT480-GW-i, NPT480-GHW-i

Input: 2.20 A; output: 2.00 A

Additional information (if necessary)

- UL (US), 333 Pfingsten Rd IL 60062, Northbrook, USA
- UL (Demko), Borupvang 5A DK-2750 Ballerup, DENMARK
- UL (JP), Marunouchi Trust Tower Main Building 6F, 1-8-3 Marunouchi, Chiyoda-ku, Tokyo 100-0005, JAPAN
- UL (CA), 7 Underwriters Road, Toronto, M1R 3B4 Ontario, CANADA

For full legal entity names see www.ul.com/ncbnames

Date: 2021-05-06

Original Issue Date: 2020-11-17

Signature:


Jan-Erik Storgaard

NPT780-i, NPT780-H-i, NPT780-W-i, NPT780-HW-i,
NPT780-i-G, NPT780-GH-i,
NPT780-GW-i, NPT780-GHW-i
Input: 3.58 A; output: 3.25 A

NPT1000-i, NPT1000-H-i,
NPT1000-W-i, NPT1000-HW-i,
NPT1000-i-G, NPT1000-GH-i,
NPT1000-GW-i, NPT1000-GHW-i
Input: 4.51 A; output: 4.10 A

NPT1200-i, NPT1200-H-i,
NPT1200-W-i, NPT1200-HW-i
Input: 5.94 A; output: 5.40 A

NPT1500-i, NPT1500-H-i,
NPT1500-W-i, NPT1500-HW-i
Input: 7.15 A; output: 6.50 A

NPT2000-i, NPT2000-H-i,
NPT2000-W-i, NPT2000-HW-i
Input: 9.35 A; output: 8.50 A

Additional Information:

Additionally evaluated to EN 61558-2-1:2007 and EN 61558-1:2005/A1:2009 ; National differences specified in the CB Test Report.

The original report was modified to include the following changes/additions:
To add new models. See Test Report.

Additional information (if necessary)




- UL (US), 333 Pfingsten Rd IL 60062, Northbrook, USA
- UL (Demko), Borupvang 5A DK-2750 Ballerup, DENMARK
- UL (JP), Marunouchi Trust Tower Main Building 6F, 1-8-3 Marunouchi, Chiyoda-ku, Tokyo 100-0005, JAPAN
- UL (CA), 7 Underwriters Road, Toronto, M1R 3B4 Ontario, CANADA

For full legal entity names see www.ul.com/ncbnames

Date: 2021-05-06
Original Issue Date: 2020-11-17

Signature:


Jan-Erik Storgaard